



NOTES

1) INSTRUMENTS IN SKID 48-SH-11001 ARE CONNECTED TO JUNCTION BOX 48-JZ-11001

48-PIT-11210 48-PIT-11214 48-PIT-11218
 48-PIT-11211 48-PIT-11215 48-PIT-11219
 48-PIT-11212 48-PIT-11220
 48-PIT-11213 48-PIT-11221

AND JUNCTION BOX 48-JK-11001

48-XY-11210 48-XY-11216
 48-XY-11212 48-XY-11217
 48-XY-11213 48-XY-11218
 48-XY-11214 48-XY-11215
 48-XY-11215

TAG ZSHL CHANGED INTO ZSH/L

- LEGEND**
- GAS DETECTOR (TWO LEVEL ALARM)
 - FLAME DETECTOR, IR
 - ⊗ FIRE DETECTOR THERMAL (RATE OF RISE)
 - GAS LINE DETECTOR
 - MAB MANUAL FIRE ALARM CALLPOINT
 - MDR MANUAL DELUGE RELEASE
 - XY SOLENOID VALVE
 - PT PRESSURE TRANSMITTER
 - ⊠ JUNCTION BOX
 - ESD II ESD II PUSHBUTTON
 - * TEMPORARY EQUIPMENT

DRAWING No	REFERENCE DRAWING

REV No	DESCRIPTION OF REVISION	ISSUE DATE	MADE BY	CHK'D BY	DISC APPR	PROJ APPR	CLIENT APPR
Z	AS BUILT	08 11 02					
Z1	AS BUILT	14 03 03					
Z2	AS BUILT, AFA F3409	07 12 06	RJM	HS	JF		OJR
Z3	AS BUILT, MW-7728	24 09 07	ILF	HS			OJR
Z4	AS BUILT, VAFA-003572	01 07 10	NHH	IOV	OA		OJR

2/11 VALHALL FLANK SOUTH

FIRE & GAS LAYOUT
CELLAR DECK
EL. +23 500

REGISTRATION CODES			DRAWING NO				SCALE
AREA	SYSTEM	TYPE	FACILITY CODE	ORIG	DISP	SEQ No	SHEET
W20	49	XE	FS - HT - I - 7002 - 005				Z4

Field for file specification. Field for date and time. Automatically inserted during plot.