


NOTES
 1. AREA CLASSIFICATION IS IN ACCORDANCE WITH IP-15 'AREA CLASSIFICATION CODE FOR PETROLEUM INSTALLATIONS' AND EQUIPMENT SHALL BE SUITABLE FOR GAS GROUP 11A TEMP. CLASS T3.
 2. EXISTING HAZARDOUS AREAS NOT SHOWN.



Granherne Limited
 CHESTER HOUSE, 76/86 CHERTSEY ROAD, WOKING, SURREY GU21 3BU
 Telephone 01483 729661 Telex 859535 INTCOM G Fax 01483 750418

Rev.	Description	Date	Drawn	Chk.	Appr.
1	CLIENTS COMMENTS INCORPORATED	23.11.96	KB	SB	
2	ISSUED FOR IDC	24.5.96			

Date	Checked	Date	Approved	Date	2	Date	3	Date	4

Amoco Norway Oil Company
 EKOFISK II MODIFICATION PROJECT
 FRONT END ENGINEERING AND DESIGN
 VALHALL WELHEAD PLATFORM
 MODULE AREA CLASSIFICATION
 MAIN DECK
 Drawing No: 00-07-00-FS-022
 Rev: A
 Sheet 1 of 3